

Star Martin

Algas Test Filter



Algas Test Filter

General Information:

The ALGAS test unit is normally delivered on a trailer, or if by sea and air, in a container. For loading and unloading it will be necessary to use a forklift with long forks.

Weight of the test unit:

Empty 650 kg Filled with water approx. 1000 kg Dimension: L = 1570 mm, W = 1385 mm, H = 1330 mm

Accessories:

Electro magnetic flowmeter Spray water pump Supply pump Polymer proportioning pump Various flexible piping 6 replacement segments with suitable filter cloths **Types of filter cloths available:** 10µ, 20µ, 30µ, 40µ, 80µ, 100µ, 120µ, 285µ, 425µ, 1000µ

10μ, 20μ, 30μ, 40μ, 80μ, 100μ, 120μ, 285μ, 425μ, 1000μ Base frame: Steel with height 1200 mm.

Mechanical Installation:

The ALGAS test unit can be installed on the ground or on the steel base frame. Please ensure that the unit is leveled. Inlet supply and outlets operates through fire hoses with express coupling.

Supply and cloudy filtrate – diameter 1½" Outlet clear filtrate and reject diameter 4" Please provide fresh water for filling up and cleaning the test filter unit.



Test Unit

Electrical connections/Electricity:

Main drive including spray water pump: 380 Volt – 32 Amp Fan (if necessary): 380 Volt – 16 Amp Polymer proportioning pump for chemicals: 380 Volt – 16 Amp Supply pump (if necessary) 380 Volt – 16 Amp

Samples:

It is recommended to take regular samples of supply, clearfiltrate and reject during the trials. The results should be noted in the table. In addition, for every sample we need the speed and rotation of the filter drum, the level difference between inside and outside of the drum and also measurements of the inlet, clearfiltrate, cloudy and reject flows.





Cellwood GmbH, Am Langen Graben 17b, 523 53 Düren, Germany



E-MAIL

info@cellwood.de www.cellwood.de